

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204958
Address: 4404 SW TANZANITE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------------|-----------|--------------------------|
| Occupancy Inspection - Codes Residential | Patrick Schonfeldt | Not Ready | Monday, October 11, 2021 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | Final grading and sod Repair unused siding bore by gas meter Seal all siding penetrations, seal along top of AC disconnect and meter can Label all dedicated receptacles in garage and unfinished basement as not GFCI protected Dishwasher receptacle requires GFCI protection Secure exterior receptacle to box near AC Splash blocks at all downspout and sump pump discharge locations, min 36" distance from foundation |
|---|------|--|

Comments: