

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204535
Address: 2029 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Monday, October 11, 2021

Corrective Action Required:

1	Miscellaneous Correction	Provide address of contrasting color of trim Obtain irrigation permit and submit backflow results Sidewalk inspection pending Provide final grade & sod & splash blocks Provide switch cover plate near SGD Complete spinals stairway to basement Provide back-flow device at water shut off near water heater Provide deck beam to post connection SE post Remove paper from insulation unfinished basement spaces or cover with approved retardant Provide deadbolt front door Seal top of exterior light fixtures
---	--------------------------	--

Comments: