

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211416  
Address: 1909 NE CATALINA AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Adam Nacke	Passed	Monday, October 11, 2021

Informational: 1 Misc	Forms are in place and aggregate is present and compacted. No sidewalk
Informational: 2 Misc	Driveway looks good and has expansion joints at curb and right of way. Right at 36ft

**Comments:**