

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200773
Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Robb Popp	Passed	Friday, October 08, 2021

Informational:

1	Miscellaneous Correction	-CORRIDOR WALLS OF 1 HOUR STORAGE ROOM OK
---	--------------------------	---

Corrective Action Required:

2	Miscellaneous Correction	-Seal around ductwork in storage room
---	--------------------------	---------------------------------------

Comments: