

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200773
Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Monday, October 11, 2021

Corrective Action Required:

1	Miscellaneous Correction	<ul style="list-style-type: none">-Label units and disconnect at rooftop-Secure raceways within 12" of disconnect at rooftop-Ensure labels for panels and breakers for RTUs are in place-Stair risers to be no more than 3/8" difference-Schedule engineering and planning for final as necessary-Complete all items for FDP and other departments as required
---	--------------------------	---

Comments: