

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211296
Address: 3118 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Monday, October 11, 2021

Corrective Action Required:

1	Misc	-fir out and down at HVAC for insulation at garage ceiling and wall -add stud shoes DWV kitchen exterior wall -secure all vertical DWV 2" or less at mid point -see 2nd floor
---	------	---

****OK TO INSULATE****

Comments: