

David P. Ainsworth, P.E.
1200 NW Hearnese Ave, Blue Springs, MO 64015
Cell Phone: 816-682-2093
Email: dainsworth@chelepis.com

October 7, 2021

Mr. Mark Yancik
508 NW Manor Drive
Blue Springs, MO 64014

Re: Property @
157 NW Carson Dr
Lee's Summit, MO
Trumark Permit # 2020-3793
W18x35 Stl Bm Substituted for triple LVL

Dear Mr. Yancik:

Substitution of a W18x35 Steel Beam for the 3 @ 1.75" x 24" LVL's spanning from the Kitchen wall to the exterior Great Room Wall is acceptable.

The W18x35 Steel Beam is more than capable of supporting the imposed loads.

Cordially,



David P. Ainsworth, P.E.

