

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204524
Address: 2037 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Failed	Tuesday, October 12, 2021

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- exterior incomplete, missing stucco at deck. Open box at deck outlet.- Open electrical box ceiling of entry.-missing joist hanger nails at deck.- secure deck post to post anchor.- attic access in garage is 1/2 rock provide 5/8" rock, leave open for inspection.-breaker 11 on main panel will not stay open.- Pay fees- sod, final grade, check water meter, splashblocks.- no sidewalk.install erosion control.
---	------	--

Comments: