

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204524

Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Failed	Tuesday, October 12, 2021

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- exterior incomplete, missing stucco at deck. Open box at deck outlet.- Open electrical box ceiling of entry.- missing joist hanger nails at deck.- secure deck post to post anchor.- attic access in garage is 1/2 rock provide 5/8" rock, leave open for inspection.- breaker 11 on main panel will not stay open.- Pay fees- sod, final grade, check water meter, splash blocks.- no sidewalk.- garage step over 3/8 difference at top step.
---	------	---

Comments: