

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211236
Address: 2163 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mark Harding	Not Ready	Tuesday, October 12, 2021

Corrective Action Required:

1	Misc	-7/12/21 GARAGE PORTAL OK TO COVER, NO TRUSS PLANS ON SITE FOR COVERED PORCH/DECK INSPECTION
---	------	--

Corrective Action Required:

2	Miscellaneous Correction	- INSPECTION DENIED - - NO TRUSS CITY APPROVED TRUSS LAYOUT & DETAIL PACKAGE ON SITE - - EROSION CONTROL FAILED -
---	--------------------------	---

Corrective Action Required:

3	Misc	3rd time- provide full set of plans at time of inspection.
---	------	---

2 fees

Comments: