

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211433  
Address: 107 NW JOSHUA DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mark Harding	Failed	Tuesday, October 12, 2021

Corrective Action Required:

1	Misc	See note on front sidelights. -Exterior walls not connected at top plates at garage/entry and entry/ bed 2 ( solid block & nail per code )  -Have engineer address foundation wall crack from beam pocket slab at north wall-daylight visible through crack ( NO ENGINEER LETTER UPLOADED TO PERMIT )
---	------	---

**Comments:**