

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210948
Address: 306 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Adam Nacke	Passed	Tuesday, October 12, 2021

Informational:	
1 Misc	Forms are in place and aggregate is present and compacted.
Informational:	
2 Misc	10-12-21 AN sidewalk looks good and meets ADA specs

Comments: