

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210837
Address: 2038 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Adam Nacke	Passed	Tuesday, October 12, 2021

Informational:

1 Misc

Forms are in place and aggregate is present and compacted.

Informational:

2 Misc

10-12-21 AN driveway looks good and has expansion joints at curb and right of way and meets ADA spec

Comments: