

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20204958
Address: 4404 SW TANZANITE CIR, LEES SUMMIT, MO 64082
Inspected On: Tuesday, October 12, 2021
Inspected By: Robb Popp
Expiration Date: 11/9/2021 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Temporary C of O	Tuesday, October 12, 2021

Corrective Action Required:

1	Misc	TCO UNTIL 11-9-21
---	------	-------------------

10-12-21

RESTORE AND MAINTAIN EROSION CONTROL AT PERIMETER OF LOT
AND CLEAN MUD AND DEBRIS FFOM STREET AND STOM INLET
IMMEDIATELY

Final grading and sod

Splash blocks at all downspout and sump pump discharge locations,
min 36" distance from foundation