

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20212244
Address: 890 NE LANGSFORD RD, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection	John Jackson	Partial	Tuesday, October 12, 2021

Informational:

1 Misc

Informational:

2 Misc

10/12/21 Tuesday (Kissick Const.)
Sanitary tie-in with 8"X6" wye & 2 hardback Fernco on the Existing "8 clay pipe. 11' to the 6" wye and 7' more to the 6" 22.5 bends. Contractor change the lateral from the 6" wye from a 22.5 to a 45deg bend. From the 22.5 to the next wye is approximately 90' of 26 SDR. Clean-out directly from the Wye and the lateral line going to the building.

Comments: