

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20211560
Address: 464 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Michael Harkins	Failed	Wednesday, October 13, 2021

Corrective Action Required:

1	Miscellaneous Correction	VENT BATH EXHAUST TO DAYLIGHT OPEN J BOXES ABOVE WASHING MACHINE AND STORAGE ROOM LAUNDRY
---	-----------------------------	--

Comments: