

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214024
Address: 4729 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Khanh Nguyen	Not Ready	Wednesday, October 13, 2021

Corrective Action Required:

1	Misc	**10/13-NOT READY FEE ASSESSED.
		-ADDRESS NOT POSTED -SHALL BACKFILL AT SEVERAL POINTS TO PROVIDE FULL VISUAL VIEW OF THE PLUMBING

Comments: