

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214148
Address: 1736 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Failed	Wednesday, October 13, 2021

Corrective Action Required:		
1	Miscellaneous Correction	PROVIDE BOCA PLATES WHERE REQUIRED SUPPORT VERTICAL DWV 2" & SMALLER AT MIDPOINT

Comments: