CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212715

Address: 4717 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Underslab Plumbing Inspection Khanh Nguyen Failed Wednesday, October

- Residential 13, 2021

Corrective Action Required:

1 Misc -Vent shower trap. FYI: each trap must connect individually to the wet-vented

horizontal drain.

Comments: