

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204780
Address: 2025 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Failed	Wednesday, October 13, 2021

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- pay re-inspection fees.- exterior : sod, final grade, all exterior items.- submit as-graded plot plan.-secure Ac whip.- missing outlet at patio. open box.-deck stairs are over 7 3/4"
---	------	---

Comments: