CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204762

Address: 2021 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Mark Harding Failed Wednesday, October

Residential 13, 2021

Corrective Action Required:

1 Misc -pay all re-inspection fees.

- submit as-graded plot plan.

- check all exterior items, water meter etc.

- uncover manhole front east side.

deck stairs over 7 3/4"
missing light master ceiling
sheetrock shelf platform garage.
support pex piping at water heater.
install anti-siphon on hose bib basement.

- provide engineers report on continous deck post.

- secure AC whip

Comments: