

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20211138  
Address: 1201 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Vacuum</b>	Ronald Paynter	Partial	Wednesday, September 29, 2021

Corrective Action Required:

1	Misc	All manholes except 5-A4 passed their vacuum test. They replaced a busted ring on 5-A4, but it still failed. They water plugged the manhole and we will retest it on Friday. RP 9-29-21
---	------	---

On Friday 10/8/2021 MH5-A4 passed the vacuum test DJ

**Comments:**