

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212715  
Address: 4717 NE FREEHOLD DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Adam Nacke	Failed	Wednesday, October 13, 2021

Corrective Action Required:

1	DCM2 ESC DEFICIENT INSTALLATION	DEFICIENT EROSION CONTROL INSTALLATION. PROVIDE GRAVEL AT LOT ENTRANCE. RE-INSTALL EROSION CONTROL AND CLEAN UP THE STREET AFTER WATER IS DONE
---	---------------------------------------	--

NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED.

Corrective Action Required:

2	Misc	Erosion control needs to be put in place!!
---	------	--

**Comments:**