

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20211138
Address: 1201 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Vacuum	Ronald Paynter	Passed	Thursday, October 14, 2021

Corrective Action Required:

1	Misc	All manholes except 5-A4 passed their vacuum test. They replaced a busted ring on 5-A4, but it still failed. They water plugged the manhole and we will retest it on Friday. RP 9-29-21
---	------	---

On Friday 10/8/2021 MH5-A4 passed the vacuum test DJ

Comments: