

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20211620  
Address: 2329 SW OLD PORT RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Thursday, October 14, 2021

Informational:

1	Misc	8-12-21
		Portal frame exterior ok to cover

Corrective Action Required:

2	Misc	-Fb all floor penetrations throughout -Provide attic access for attic space above garage exceeding 30 sq ft -Protect plumbing at half bathroom bottom wall plate -Toe nail all joists to wall top plates -Provide wall receptacle spacing at living room stair wall per code -Nail studs at intersections -Complete building wall at master shower -Install hanger at 2x12 ceiling beam connection above master closet switch -Complete gas piping system and bonding
---	------	---

**\*\*DO NOT INSULATE**

**Comments:**