

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211621
Address: 2333 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Thursday, October 14, 2021

Corrective Action Required:

1	Misc	8-12-21 Portal frame exterior ok to cover
---	------	--

Corrective Action Required:

2	Misc	<ul style="list-style-type: none">-Nail garage PFH wall sheathing to sill plate w/8d@3" oc-Fb all floor penetrations throughout ; fb duct chase at half bathroom from joist space-Protect plumbing at half bathroom bottom wall plate-Toe nail all joists to wall top plates-Support front porch roof ridge-Provide 5 stud support for beam at stair wall-Provide wall receptacle spacing per code at 1st fl stair wall-Fb excessive gap at top of wall of bedroom 2 closet-Support ceiling framing above master bedroom
---	------	--

****DO NOT INSULATE**

Comments: