

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211621
Address: 2333 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Khanh Nguyen	Failed	Thursday, October 14, 2021

Corrective Action Required:

1	Misc	-Connect the grounding electrode conductor to the middle grounded bus bar or install jumper (#4 cu or #2 al) from the EGC bus bar to the grounded bus bar. -Secure all wirings at panel connectors.
---	------	--

Comments: