

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20210775
Address: 1201 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Air Test	Ronald Paynter	Partial	Wednesday, September 29, 2021

Informational:

1 Misc

From manhole 5-B1 to manhole 6-A2, the sanitary lines passed their air test.
RP 9-29-21

On Friday 10/8/2021 DJ
Sanitary Sewer Air Test Passed:
From MH 6-C1 to MH 6-C2;
From MH 6-C2 to MH 6-C3;
From MH 6-C4 to MH 6-C5;
From MH 6-C4 to MH 6-E1.

Sanitary Sewer Air Test Failed:
MH 6-A1 to MH 6-C1

Comments: