

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSUBD20210775  
Address: 1201 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                      | Inspector:     | Outcome: | Date:                      |
|----------------------------------|----------------|----------|----------------------------|
| <b>Sanitary Sewer - Air Test</b> | Ronald Paynter | Passed   | Thursday, October 14, 2021 |

Informational:  
1            Misc            From manhole 5-B1 to manhole 6-A2, the sanitary lines passed their air test.  
RP 9-29-21

**SANITARY SEWER AIR TEST PASSED:**

From MH 6-C1 to MH 6-C2;  
From MH 6-C2 to MH 6-C3;  
From MH 6-C4 to MH 6-C5;  
From MH 6-C4 to MH 6-E1.

**SANITARY SEWER FAILED:**

MH 6-A1 to MH 6-C1

Informational:  
2            Misc            All remaining sanitary lines passed their air testing. RP 10-14-21

**Comments:**