

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20210775
Address: 1201 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Vacuum	Ronald Paynter	Passed	Thursday, October 14, 2021

Corrective Action Required:

1	Misc	Manhole 6-A1 failed and manhole 6-A2 passed their vacuum test. RP 9-29-21
		On Friday MH 6-C1, MH 6-C2, MH 6-C4, and MH 6-E1 passed the vacuum test at 10 psi for 3 mins
		MH 6-C3 failed the vacuum test. DJ

Informational:

2	Misc	All manholes passed their vacuum testing. RP 10-14-21
---	------	---

Comments: