

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRRES20210124  
**Address:** 1526 SW BLACKSTONE PL, LEES SUMMIT, MO 64082  
**Inspected On:** Friday, October 15, 2021  
**Inspected By:** Patrick Schonfeldt  
**Expiration Date:** 10/29/2021 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Temporary C of O	Friday, October 15, 2021

**Corrective Action Required:**

1	Misc	-No pier inspection performed, submit engineer report -Final grade and sod -Gutters, downspouts, Splash blocks at all downspout and sump pump discharge, minimum 36" discharge from foundation - seal all penetrations in siding, seal along top of meter can and AC disconnect
---	------	--

\*\*\*OK FOR TCO - TCO EXPIRES 10/29/21\*\*\*