

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20204535
Address: 2029 NW ASHURST DR, LEES SUMMIT, MO 64081
Inspected On: Friday, October 15, 2021
Inspected By: Michael Harkins
Expiration Date: 11/12/2021

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

| Inspection: | Inspector: | Outcome: | Date: |
|---|-----------------|------------------|-----------------------------|
| Occupancy Inspection - Codes Residential | Michael Harkins | Temporary C of O | Friday, October 15, 2021 |

Corrective Action Required:

| | | |
|---|-----------------------------|--|
| 1 | Miscellaneous Correction | Obtain irrigation permit and submit backflow results Sidewalk inspection pending Provide final grade & sod & splash blocks Provide deck beam to post connection SE post |
|---|-----------------------------|--|