

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20204900
Address: 1460 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Joe Starlin	Partial	Saturday, October 16, 2021

Informational:
1 Misc

10/07/21 Thursday
Commercial sidewalk were installed in the front and South side of Whataburger on 10/05/21.
10/16/21 Saturday (Artistic Concrete Design Const.)
Contractor Poured the drive thru/ walkway and diagonal concrete pad in island around Whataburger.
Special note: ADA Ramp connected to Whataburger's sidewalk leading to the parking lot is not compliant. Landing Pad will be only 5'X3'. I discussed with Gregg the Superintendent of site and the concrete Subcontractor (Artistic Concrete) about the non-compliance, and they told me (Field Inspector John M. Jackson) "Whataburger's corporation ADA Engineer specialist to install 5'X3' as-per plans.

Comments: