

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211896
Address: 4716 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Partial	Monday, October 18, 2021

Corrective Action Required:

1	Misc	-Nail exterior wall siding and sheathing to per code
		-Install spark ring at outdoor receptacle box near AC
		-Drive the grounding rod down into earth
		**OK TO ROCK

Comments: