



PLAN REVIEW CONDITIONS

October 19, 2021

SULLIVAN PALMER ARCHITECTS
8849 LONG
LENEXA, KS 66215

Permit No: PRCOM20215409
Project Title: TWISTED FRESH
Project Address: 940 NW PRYOR RD, Unit:A, LEES SUMMIT, MO 64081
Parcel Number: 51800043700000000
Location: STREETS OF WEST PRYOR LOTS 1-14 & TRACTS A-D: LOT 8 (EX TH PT LOT 8 DAF: ALL TH SPACE BETWEEN NAVD8 DEG 27 MIN 16 MIN W 41.99' TO TRU POB TH S 87 DEG 32 MIN 44 SEC E 27.69' TH N 02 DEG 27 MIN 16 SEC E E 29.33' TH S 02 DEG 27 MIN 16 SEC W 36' TH N 87 DEG 32 MIN 44 SEC W 2' TH S 02 DEG 27 MIN 16 SEC W W 4' TH S 02 DEG 27 MIN 16 SEC W 22.67' TH S 87 DEG 32 MIN 44 SEC E 4.67' TH S 02 DEG 16 MIN 27 SEC
Type of Work: NEW TENANT FINISH
Occupancy Group: ASSEMBLY FOR FOOD AND DRINK INC BARS, RESTAURANTS, BANQUET HALLS
Description: TENANT FINISH FOR NEW RESTAURANT

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Pending

Fire Plan Review

Reviewed By: Michael Weissenbach

Approved with Conditions

1. 2018 IFC 1004.3- Posting of occupant load. Every room or space that is an assembly occupancy shall have the occupant load of the room or space posted in a conspicuous place, near the main exit or exit access doorway from the room or space. Posted signs shall be of an approved legible permanent design and shall be maintained by the owner or authorized agent.

(Verified At Inspection)

Post occupant load signage at 62.

2. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. .A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and

materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.
(Action Required)

Any modifications to the fire alarm system, provide PE stamped electronic shop drawings to
mike.weissenbach@cityofls.net

3. 2018 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

(Action Required)

Any modifications to the fire sprinkler system, provide PE stamped electronic shop drawings to
mike.weissenbach@cityofls.net

4. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule alarm and hood testing.

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.