

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20210103  
Address: 2100 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Adam Nacke	Partial	Tuesday, October 19, 2021

Informational: 1 Misc	Sidewalk on independence. Form are in place and aggregate is present and compacted. One soft spot that needs to be addressed
Informational: 2 Misc	Sidewalk on Town Center is getting moved do to ground elevation and will now be placed connected to the curb. The sidewalk will be 6ft wide and there will be multiple jogs in the sidewalk do to a fire hydrant and manhole .
Informational: 3 Misc	Front drive on town center dr has been completed and meets ADA spec. Still need to check the east side sidewalk and the west side is still under construction.
Informational: 4 Misc	Front drive on town center dr has been completed and meets ADA spec. Still need to check the east side sidewalk and the west side is still under construction.

**Comments:**