CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #:PRRES20213052Address:3819 SW WALSH DR, LEES SUMMIT, MO 640823817 SW WALSH DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection - R	Mark Harding	Failed	Tuesday, October 19, 2021

Corrective Action Required:

Misc both sides of footing where the sewer was excavated is undermined provide engineers report on undermined footing.

Comments:

1