

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210596
Address: 2102 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Adam Nacke	Passed	Tuesday, October 19, 2021

Informational:
1 Misc 10-14-21 AN forms are in place and aggregate is present and compacted . Informed contractor that some spots were not deep enough for the 6" of concrete.

Informational:
2 Misc Driveway looks good and has expansion joints at curb and right of way. No sidewalk

Comments: