

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20200773
Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063
Inspected On: Tuesday, October 19, 2021
Inspected By: Robb Popp
Expiration Date: 11/16/2021 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Temporary C of O	Tuesday, October 19, 2021

Corrective Action Required:

1	Miscellaneous Correction	-Complete all items for FDP and other departments as required
---	-----------------------------	---

Planning - LIGHT FIXTURES. Two wall-mounted light fixtures off the northeast and northwest building corners do not satisfy ordinance requirements for full cut-offs, nor do they match the cut sheets provided as part of the approved final development plan.

Field Engineering - Vegetation