

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213583

Address: 3825 SW WALSH DR, LEES SUMMIT, MO 640823823 SW WALSH DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, October 19, 2021

Corrective Action Required:

1	Misc	FOOTING HAS BEEN UNDERMINED ALONG RIGHT SIDE OF HOUSE FOR SEWER LINE TRENCH, SUBMIT ENGINEER REPORT
---	------	---

Comments: