

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20210775
Address: 1201 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Mandrel	Ronald Paynter	Passed	Tuesday, October 19, 2021

Informational:
1 Misc

On Friday 10/8/2021 DJ
Sanitary Sewer Mandrel Test Passed:
From MH 6-C1 to MH 6-C2;
From MH 6-C2 to MH 6-C3;
From MH 6-C4 to MH 6-C5;
From MH 6-C4 to MH 6-E1.

Sanitary Sewer Not Tested:
MH 6-A1 to MH 6-C1

Informational:
2 Misc

The mandrel passed through all sanitary lines. RP 10-18-21

Comments: