

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210837  
Address: 2038 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection</b>	Mark Harding	Failed	Wednesday, October 20, 2021

Corrective Action Required:

1	Misc	IDENTIFY UFER GROUND BOTH ENDS, UFER GROUND REQUIRED, SEE LOCATION NOTED AT FOOTING, FOUNDATION WALL FT STOOP/GARAGE - LOCATE UFER & GROUND SERVICE PANEL - - UFER LOCATION NOTED ON FOOTING INSPECTION FIND IT Michael Harkins 08/12/2021 9:54 AM ( 2018 IRC E3608.1.2)
---	------	--

Corrective Action Required:

2	Misc	email sent to Mark : locate the CCE and reschedule for inspection.
---	------	--

**Comments:**