

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210599
Address: 2051 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	Michael Harkins	Passed	Wednesday, October 20, 2021

Informational:
1 Misc - WELDS APPROVED BOTH DUCTS FOR 1ST LAYER OF WRAP -
- 1ST LAYER WRAP APPROVED FOR 2ND LAYER -
- 2ND LAYER WRAP APPROVED -

Comments: