

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20212196  
Address: 1630 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Curb - Proof Roll</b>	Adam Nacke	Failed	Wednesday, October 20, 2021

Corrective Action Required:

1	Misc	10-19-21 AN did curb proof roll on 7th and 8th plat. There were 3 bad spots, 1 about 500ft up the hill on ne park springs dr and 2 bad spots at the entrance of ne park springs terrace. Contractor to fix bad spots .
---	------	--

**Comments:**