PLANS REVIEW CONDITIONS

Permit No: PRCOM20210427 Date: October 20, 2021

Project Title: PETSUITES OF AMERICA Applicant:

Location:

250 NW MCNARY CT, LEES SUMMIT, MO 64086 ADVANTAGE FIRE PROTECTION SYSTEMS INC

Type of Work: 404 B NW 11TH ST

Occupancy Group: B BLUE SPRINGS, MO 64015

Description: NEW BUILDING PET BOARDING AND

DAYCARE FACILITY WITH SPACE FOR FUTURE VET CLINIC Primary: (816) 224-3400

(PRCOM20211647)

Construction Type: Type IIB (Unprotected)

Map Page:

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review Reviewed By: Michael Weissenbach Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test. (Informational Purposes)

Call (816)969-1300 to schedule a hydrostatic and waterflow test.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.