

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210350
Address: 1425 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, October 20, 2021

Corrective Action Required:

1	Misc	-guard rail required at front stoop more than 30" from grade -obtain lawn irrigation permit -pay all fees before next inspection. -finish electrical above fireplace and add spark ring -security screws at back door two for each hinge and strike plate. -self closing door at garage -open electrical (garage ceiling) -add support for handrail at basement -complete front exterior lighting
---	------	--

Comments: