

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20202286
Address: 2020 SW HOOK RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Punch List Inspection	John DiMauro	Partial	Monday, September 27, 2021

Informational:

1 Misc

On Monday, 9-27-2021. Red Ford Excavating completed punch list items given by water Service. Only only item remains to be completing. (1) Man Hole adjustment

On Wednesday, 10-20-2021. Red Ford Excavating completed the final punch list item for this project. Contractor completed removal of the broken riser ring for the identified man hole and replaced the riser. (1) 8" reinforced concrete 6 x 6 pad was installed around the man hole.

Comments: