

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214591
Address: 1103 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Ronald Paynter	Partial	Wednesday, October 20, 2021

Informational:

1 Misc

Construction entrance is using the old existing asphalt. Rieke Grading was digging on the building pad and trucks were transferring some debris into Oldham Parkway. Talked with from Joe from Rieke Grading and Gary White with Harmon Construction about keeping Oldham clean. They also need to add protection for storm flumes. RP 10-20-21

Comments: