

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213953  
Address: 1517 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection - Residential</b>	Mitchell Schwarz	Failed	Wednesday, October 20, 2021

Corrective Action Required:

1	Misc	*NO ADDRESS POSTED*
NO INSPECTION DUE TO FOOTING INSPECTION NOT COMPLETE		

**Comments:**