

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRPR20214162
Address: 1153 NE RICE RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Khanh Nguyen	Failed	Thursday, October 21, 2021

Corrective Action Required:

1	Misc	-install main bonding jumper connecting the service grounded conductor to enclosure&EGC -provide grounding clamp listed for aluminum conductor
---	------	---

Comments: